



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Shrewsbury Boro, 20 Obre Place, Shrewsbury, NJ
PAS Project ID : P22-08370

Matrix : Drinking Water
Report Date : 8/2/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-08370-01	Field Blank 1952	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:18	8/1/22 12:13
P22-08370-02	1. SB #1 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:19	8/1/22 12:17
P22-08370-03	2. SB #2 FP Sink BA 415	Lead	25.7	ug/L	4	8.00	3.60	15.0 *	SM 3113 B	7/29/22 07:20	8/1/22 15:05
P22-08370-04	3. SB #3 DW	Lead	10.5	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:22	8/1/22 12:45
P22-08370-05	4. SB #4 DW	Lead	4.75	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:23	8/1/22 12:49
P22-08370-06	5. SB #5 DW	Lead	4.99	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:23	8/1/22 12:53
P22-08370-07	6. SB #6 IM Ice	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:25	8/1/22 12:57
P22-08370-08	7. SB #7 FP Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:29	8/1/22 13:01
P22-08370-09	8. SB #8 DW Hall 501	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:30	8/1/22 13:05
P22-08370-10	9. SB #9 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:32	8/1/22 13:09
P22-08370-11	10. SB #10 DW	Lead	8.35	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:34	8/1/22 13:13
P22-08370-12	11. SB #11 FP Sink (Library)	Lead	1.63 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:35	8/1/22 13:26
P22-08370-13	12. SB #12 FP Nurse Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:45	8/1/22 13:30
P22-08370-14	13. SB #13 DW Filter	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:47	8/1/22 13:34
P22-08370-15	15. SB #15 DW Rm 306	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:49	8/1/22 13:38
P22-08370-16	17. SB #17 DW	Lead	2.11	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:52	8/1/22 13:42
P22-08370-17	18. SB #18 DW	Lead	1.87 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:52	8/1/22 13:46
P22-08370-18	20. SB #20 DW SS	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:54	8/1/22 13:51
P22-08370-19	Field Blank Addition 2004	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 07:57	8/1/22 13:55
P22-08370-20	23. SB #23 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 08:00	8/1/22 13:59
P22-08370-21	24. SB #24 FP Sink Kitchen	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 08:03	8/1/22 14:11
P22-08370-22	25. SB #25 FP Sink Kitchen	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 08:03	8/1/22 14:27
P22-08370-23	26. SB #26 203 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 08:05	8/1/22 14:31
P22-08370-24	27. SB #27 202 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 08:08	8/1/22 14:35
P22-08370-25	28. SB #28 201 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 08:09	8/1/22 14:39
P22-08370-26	29. SB #29 DW 307	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 08:12	8/1/22 14:43
P22-08370-27	30. SB #30 DW K Wing	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/29/22 08:15	8/1/22 15:01

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Shrewsbury Boro BOE, 20 Obre Place
PAS Project ID : P22-09745

Matrix : Drinking Water
Report Date : 8/26/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-09745-01	SB #2 FP Sink BA 415 1st Draw	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/23/22 09:16	8/25/22 13:25
P22-09745-02	SB #2 FP Sink BA 415 Flush	Lead	1.58 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/23/22 09:17	8/25/22 13:29

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director

Appendix D
Excel Template for Lead Results

Client : Strategic Environmental
Project ID : Shrewsbury Boro BOE, 20 Obre Place

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method
SB #2 FP Sink BA 415 1st Draw	N	P22-09745-01	PAS	NJDEP 15001	8/23/2022	9:16	SM 3113 B
SB #2 FP Sink BA 415 Flush	N	P22-09745-02	PAS	NJDEP 15001	8/23/2022	9:17	SM 3113 B