



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Shrewsbury Boro, 20 Obre Place, Shrewsbury, NJ
PAS Project ID : P21-05332

Matrix : Drinking Water
Report Date : 6/18/2021

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P21-05332-01	Field Blank 1952	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:03	6/16/21 11:23
P21-05332-02	1. SB #1 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:03	6/16/21 11:27
P21-05332-03	2. SB #2 FP Sink (BA 415)	Lead	14.1	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:07	6/16/21 11:51
P21-05332-04	3. SB #3 DW	Lead	7.61	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:10	6/16/21 11:55
P21-05332-05	4. SB #4 DW	Lead	4.16	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:11	6/16/21 11:59
P21-05332-06	5. SB #5 DW	Lead	7.38	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:12	6/16/21 12:03
P21-05332-07	6. SB #6 IM Ice	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:14	6/16/21 12:07
P21-05332-08	7. SB #7 FP Sink	Lead	1.62 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:15	6/16/21 12:11
P21-05332-09	8. SB #8 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:19	6/16/21 12:15
P21-05332-10	9. SB #9 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:20	6/16/21 12:19
P21-05332-11	10. SB #10 DW	Lead	4.62	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:22	6/16/21 12:23
P21-05332-12	11. SB #11 FP Sink	Lead	18.9	ug/L	2	4.00	1.80	15.0 *	SM 3113 B	6/15/21 07:25	6/16/21 14:43
P21-05332-13	12. SB #12 FP Sink Nurse	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:30	6/16/21 12:39
P21-05332-14	13. SB #13 DW Filter	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:31	6/16/21 12:43
P21-05332-15	15. SB #15 DW Rm 306	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:35	6/16/21 12:47
P21-05332-16	16. SB #16 FP Sink Rm 306	Lead	2.31	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:36	6/16/21 12:51
P21-05332-17	17. SB #17 DW	Lead	3.93	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:37	6/16/21 12:56
P21-05332-18	18. SB #18 DW	Lead	3.46	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:38	6/16/21 13:00
P21-05332-19	19. SB #19 DW Ceramic	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:39	6/16/21 13:04
P21-05332-20	20. SB #20 DW SS	Lead	1.39 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:40	6/16/21 13:08
P21-05332-21	22. SB #22 Outdoor	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:44	6/16/21 13:20
P21-05332-22	Field Blank Addition 2004	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:50	6/16/21 13:36
P21-05332-23	23. SB #23 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:51	6/16/21 13:40
P21-05332-24	24. SB #24 FP Sink Kitchen	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:53	6/16/21 13:44
P21-05332-25	25. SB #25 FP Sink Kitchen	Lead	9.46	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:54	6/16/21 13:48
P21-05332-26	26. SB #26 DW 203	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:55	6/16/21 13:52
P21-05332-27	27. SB #27 DW 202	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:57	6/16/21 14:04
P21-05332-28	28. SB #28 DW 201	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 07:58	6/16/21 14:08
P21-05332-29	29. SB #29 DW 307	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 08:00	6/16/21 14:11
P21-05332-30	30. SB #30 DW K Wing	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 08:03	6/16/21 14:15
P21-05332-31	31. SB #31 DW Outside	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/21 08:04	6/16/21 14:19

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director

Appendix D
Excel Template for Lead Results

Client : Strategic Environmental
Project ID : Shrewsbury Boro, 20 Obre Place, Shrewsbury, NJ

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
Field Blank 1952	N	P21-05332-01	PAS	NJDEP 15001	6/15/2021	7:03	SM 3113 B	6/16/2021	11:23	0.240	2.00	1	N	ND
1. SB #1 DW	N	P21-05332-02	PAS	NJDEP 15001	6/15/2021	7:03	SM 3113 B	6/16/2021	11:27	0.240	2.00	1	N	ND
2. SB #2 FP Sink (BA 415)	N	P21-05332-03	PAS	NJDEP 15001	6/15/2021	7:07	SM 3113 B	6/16/2021	11:51	14.1	2.00	1	N	
3. SB #3 DW	N	P21-05332-04	PAS	NJDEP 15001	6/15/2021	7:10	SM 3113 B	6/16/2021	11:55	7.61	2.00	1	N	
4. SB #4 DW	N	P21-05332-05	PAS	NJDEP 15001	6/15/2021	7:11	SM 3113 B	6/16/2021	11:59	4.16	2.00	1	N	
5. SB #5 DW	N	P21-05332-06	PAS	NJDEP 15001	6/15/2021	7:12	SM 3113 B	6/16/2021	12:03	7.38	2.00	1	N	
6. SB #6 1M Ice	N	P21-05332-07	PAS	NJDEP 15001	6/15/2021	7:14	SM 3113 B	6/16/2021	12:07	0.700	2.00	1	N	ND
7. SB #7 FP Sink	N	P21-05332-08	PAS	NJDEP 15001	6/15/2021	7:15	SM 3113 B	6/16/2021	12:11	1.62	2.00	1	N	J
8. SB #8 DW	N	P21-05332-09	PAS	NJDEP 15001	6/15/2021	7:19	SM 3113 B	6/16/2021	12:15	0.240	2.00	1	N	ND
9. SB #9 DW	N	P21-05332-10	PAS	NJDEP 15001	6/15/2021	7:20	SM 3113 B	6/16/2021	12:19	0.240	2.00	1	N	ND
10. SB #10 DW	N	P21-05332-11	PAS	NJDEP 15001	6/15/2021	7:22	SM 3113 B	6/16/2021	12:23	4.62	2.00	1	N	
11. SB #11 FP Sink	N	P21-05332-12	PAS	NJDEP 15001	6/15/2021	7:25	SM 3113 B	6/16/2021	14:43	18.9	4.00	2	N	
12. SB #12 FP Sink Nurse	N	P21-05332-13	PAS	NJDEP 15001	6/15/2021	7:30	SM 3113 B	6/16/2021	12:39	0.240	2.00	1	N	ND
13. SB #13 DW Filter	N	P21-05332-14	PAS	NJDEP 15001	6/15/2021	7:31	SM 3113 B	6/16/2021	12:43	0.0058	2.00	1	N	ND
15. SB #15 DW Rm 306	N	P21-05332-15	PAS	NJDEP 15001	6/15/2021	7:35	SM 3113 B	6/16/2021	12:47	0.470	2.00	1	N	ND
16. SB #16 FP Sink Rm 306	N	P21-05332-16	PAS	NJDEP 15001	6/15/2021	7:36	SM 3113 B	6/16/2021	12:51	2.31	2.00	1	N	
17. SB #17 DW	N	P21-05332-17	PAS	NJDEP 15001	6/15/2021	7:37	SM 3113 B	6/16/2021	12:56	3.93	2.00	1	N	
18. SB #18 DW	N	P21-05332-18	PAS	NJDEP 15001	6/15/2021	7:38	SM 3113 B	6/16/2021	13:00	3.46	2.00	1	N	
19. SB #19 DW Ceramic	N	P21-05332-19	PAS	NJDEP 15001	6/15/2021	7:39	SM 3113 B	6/16/2021	13:04	0.470	2.00	1	N	ND
20. SB #20 DW SS	N	P21-05332-20	PAS	NJDEP 15001	6/15/2021	7:40	SM 3113 B	6/16/2021	13:08	1.39	2.00	1	N	J
22. SB #22 Outdoor	N	P21-05332-21	PAS	NJDEP 15001	6/15/2021	7:44	SM 3113 B	6/16/2021	13:20	0.0058	2.00	1	N	ND
Field Blank Addition 2004	N	P21-05332-22	PAS	NJDEP 15001	6/15/2021	7:50	SM 3113 B	6/16/2021	13:36	-0.22	2.00	1	N	ND
23. SB #23 DW	N	P21-05332-23	PAS	NJDEP 15001	6/15/2021	7:51	SM 3113 B	6/16/2021	13:40	-0.22	2.00	1	N	ND
24. SB #24 FP Sink Kitchen	N	P21-05332-24	PAS	NJDEP 15001	6/15/2021	7:53	SM 3113 B	6/16/2021	13:44	0.700	2.00	1	N	ND
25. SB #25 FP Sink Kitchen	N	P21-05332-25	PAS	NJDEP 15001	6/15/2021	7:54	SM 3113 B	6/16/2021	13:48	9.46	2.00	1	N	
26. SB #26 DW 203	N	P21-05332-26	PAS	NJDEP 15001	6/15/2021	7:55	SM 3113 B	6/16/2021	13:52	-0.22	2.00	1	N	ND
27. SB #27 DW 202	N	P21-05332-27	PAS	NJDEP 15001	6/15/2021	7:57	SM 3113 B	6/16/2021	14:04	-0.22	2.00	1	N	ND
28. SB #28 DW 201	N	P21-05332-28	PAS	NJDEP 15001	6/15/2021	7:58	SM 3113 B	6/16/2021	14:08	-0.22	2.00	1	N	ND
29. SB #29 DW 307	N	P21-05332-29	PAS	NJDEP 15001	6/15/2021	8:00	SM 3113 B	6/16/2021	14:11	-0.22	2.00	1	N	ND
30. SB #30 DW K Wing	N	P21-05332-30	PAS	NJDEP 15001	6/15/2021	8:03	SM 3113 B	6/16/2021	14:15	-0.22	2.00	1	N	ND
31. SB #31 DW Outside	N	P21-05332-31	PAS	NJDEP 15001	6/15/2021	8:04	SM 3113 B	6/16/2021	14:19	-0.46	2.00	1	N	ND

GRAM
OF
SUSTAINABLE

2101 WINDYVILLE ROAD TOMS RIVER, NJ 08785 PHONE 732-214-1515 FAX 732-214-1818

Customer: Strategic Environmental Svcs.
 Address: 25 Butternut Lane
 Bayville, NJ 08721
 Phone: (732) 269-0204

School Name: St. Ann's School
 School Address: 200 Park Road
 Sampled By: [Signature]
 Print Name: [Signature]
 RESULTS TO: SEC. Inc.

Sample ID Location	Water Time Sampled	Matrix Code	Grab or Comp	Flask Sample	Filter Preset	# Containers	Glass or Plastic	Analysis	LAB ID
Field Blank 1952	7:03	DW	Grab			1	250 ml Plastic	Lead	1952
1 SB #1 DW	7:03	DW	Grab			1	250 ml Plastic	Lead	
2 SB #2 FP SINK BA 415	7:07	DW	Grab			1	250 ml Plastic	Lead	
3 SB #3 DW	7:10	DW	Grab			1	250 ml Plastic	Lead	
4 SB #4 DW	7:11	DW	Grab			1	250 ml Plastic	Lead	
5 SB #5 DW	7:12	DW	Grab			1	250 ml Plastic	Lead	
6 SB #6 IM ICE	7:14	DW	Grab			1	250 ml Plastic	Lead	
7 SB #7 FP SINK	7:15	DW	Grab			1	250 ml Plastic	Lead	
8 SB #8 DW	7:19	DW	Grab			1	250 ml Plastic	Lead	
9 SB #9 DW	7:20	DW	Grab			1	250 ml Plastic	Lead	
10 SB #10 DW	7:22	DW	Grab			1	250 ml Plastic	Lead	
11 SB #11 FP SINK	7:25	DW	Grab			1	250 ml Plastic	Lead	
12 SB #12 FP SINK W/ICE	7:30	DW	Grab			1	250 ml Plastic	Lead	
13 SB #13 DW Filter	7:31	DW	Grab			1	250 ml Plastic	Lead	
14 SB #14 Spigot Exempt	N/T	DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED, PRESERVED IN LAB.

* All First Draw

Page 1 of 3

Deliverables:

PDF Std. X
 PDF Reduc.
 PDF Full
 PDF EDD

Date/Time Preserved with notes

4/15/2011

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, R = Solid (specify):

PREIER 0=Ice 1=HOT
 VATIVE 2=112504 3=112501
 CODES: 4=11103 5=Other

	Print Name:	Signature:	Consent:	Date + Time
Relinquished	S. Romano	[Signature]		4/15/2011
Received	Lyna Sano	[Signature]		8:51 AM
Relinquished				
Received				
Relinquished				
Received				

PRECISION ANALYTICAL SERVICES, INC.

1000 VILLAVIA DRIVE FORT LINDEN, NJ 08026 PHONE 732-614-1515 FAX 732-614-1616

CHAIN OF CUSTODY

Customer: Strategic Environmental Svcs.
 Address: 25 Butternut Lane
 Bayville, NJ 08721
 Phone: (732) 269-4204

School Name: Shrewsbury Boro
200 Park Road
 School Address: Shrewsbury NJ
 Sampled By: [Signature]
 Print Name: J Bonanno
 RESULTS TO: SEC Inc.

Sample ID Location	Date/Time Sampled	Matrix Code	Grab or Comp	Phos Sample	Free Preset	# Containers	Glass or Plastic	Analysis	LAB ID
15 SB#15 DW Rm 306	7:35	DW	Grab			1	250 ml Plastic	Lead	
16 SB#16 FP sink Rm306	7:36	DW	Grab			1	250 ml Plastic	Lead	
17 SB#17 DW	7:37	DW	Grab			1	250 ml Plastic	Lead	
18 SB#18 DW	7:38	DW	Grab			1	250 ml Plastic	Lead	
19 SB#19 DW ceramic	7:39	DW	Grab			1	250 ml Plastic	Lead	
20 SB#20 DW SS	7:40	DW	Grab			1	250 ml Plastic	Lead	
21 SB#21 Spigot Exempt	N/A	DW	Grab			1	250 ml Plastic	Lead	
22 SB#22 outdoor Field Blank. Addition 2004	7:44	DW	Grab			1	250 ml Plastic	Lead	
23 SB#23 DW	7:50	DW	Grab			1	250 ml Plastic	Lead	
24 SB#24 FP sink kitchen	7:51	DW	Grab			1	250 ml Plastic	Lead	
25 SB#25 FP sink kitchen	7:53	DW	Grab			1	250 ml Plastic	Lead	
26 SB#26 DW 203	7:54	DW	Grab			1	250 ml Plastic	Lead	
27 SB#27 DW 202	7:55	DW	Grab			1	250 ml Plastic	Lead	
28 SB#28 DW 201	7:57	DW	Grab			1	250 ml Plastic	Lead	
	7:58	DW	Grab			1	250 ml Plastic	Lead	PJ-15333-38

SAMPLES REC'D UNPRESERVED, PRESERVED IN LAB.

* All First Draw

Page 2 of 3

Deliverables:

PDF Std.	PDF Reduc.	PDF Full	EDD	04/11/16 preserved with HPLC
X				6/15/21 9:51 AM

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PREIER 0=Ice 1=JIC
 UATUE 2=12504 3=16001
 CODES: A=11103 S=Other

	Print Name:	Signature:	Capacity:	Date + Time
Relinquished:	J Bonanno SEC Inc.	[Signature]		6/15/21
Received:	[Signature]	[Signature]		9:51 AM
Relinquished:				
Received:				
Relinquished:				
Received:				

PRECISION ANALYTICAL SERVICES, INC.

2691 WHIPPOLE ROAD TOMS RIVER, NJ 08725 PHONE 732-844-1515 FAX 732-844-1818

CHAIN OF CUSTODY

Customer: Strategic Environmental Svcs.
 Address: 25 Butternut Lane
 Bayville, NJ 08721
 Phone: (732) 269-0204

School Name: Shrewsbury Public School
 School Address: 200 Park Road
Shrewsbury NJ
 Sampled By: [Signature]
 Print Name: J. Bonanno
 RESULTS TO: SEC Inc.

Sample ID Location	Date Sampled	Time Sampled	Matrix Code	Grab or Comp	Flask Temp	Flask Preserv	# Containers	Class or Plastic	Analyz Is	LAB ID
29 SB#29 DW 307	8:00	8:00 AM	DW	Grab			1	250 ml Plastic	Lead	010 0300 29
30 SB#30 DW K wing	8:03	8:03 AM	DW	Grab			1	250 ml Plastic	Lead	010 0300 30
31 SB#31 DW outside	8:07	8:07 AM	DW	Grab			1	250 ml Plastic	Lead	010 0300 31
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	
			DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

* All First Draw

PDF Std. PDF Reduc. PDF Full EDD

Date/Time Preserved with Unit: 6/16/12 @ 10:15

Page 3 of 3 Deliverables: X

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVE CODES: 0=Ice 1=HCl 2=H2SO4 3=NaOH 4=HNO3 5=Other

	Print Name:	Signature:	Number:	Date + Time
Relinquished:	J. Bonanno SEC Inc.	[Signature]		6/16/12
Received:	L. A. Souza	[Signature]	11	8:51 AM
Relinquished:				
Received:				
Relinquished:				
Received:				

Shrewsbury Boro
20 Obere Place
Shrewsbury NJ
07702

H.iv: Sampling Event Checklist
Complete on the day of sampling

Before Beginning Sampling:

- Review and Sign QAPP.
- Review School packet prior to sampling- including floor plan with sample locations, outlet inventory including all outlets to be sampled, filter inventory including which water coolers & drinking water fountains have filters, and if applicable pre-sampling event flushing schedule (includes which outlets were flushed, the duration of flushing, and when they were flushed).
- Perform a walk-through of the facility prior to sampling. Identify all outlets to be sampled, and label each outlet with its unique sample location code as it is found in the water outlet inventory.
- Verify that the water has been stagnant for at least 8 hours, but no longer than 48 hours.

Sampling:

- Field Blank.
- Start sampling at the outlet closest to the point of entry.
- For each sampling location record the time that sampling begins.
- Wearing gloves, collect samples into a 250 ml pre-cleaned bottle.
- Record the time all samples are collected.
- AFTER all other samples have been collected, for follow-up flush sampling, collect fifteen minute flushed samples from water coolers.
- Indicate on the Chain of Custody (COC) if the outlet is leaking, the water is discolored, the outlet is turned on; the outlet is not working, or the outlet has a filter.
- Label all Follow-Up Flush Samples with "FLUSH" after their unique sample location code. (e.g. WHS- and WHS ---FLUSH).

After Sampling:

- Record the time that sampling ends.
- Count sampling bottles to make sure all water outlets on the inventory were sampled.

Project Officer: Mike Tillett Mike Tillett 6/15/2021
Print Name Signature Date

Sampler: J Bonanno J Bonanno 6/10/21
Print Name Signature Date

Quality Assurance Project Plan (QAPP) For Drinking Water Sampling of Lead Concentrations in School Drinking Water Outlets

Shrewsbury Boro
200 Oak Place
Shrewsbury NJ 07702

Approvals

School District Representatives:

Program Manager: _____
Print Name Signature Date

Project Manager(s): Mike Tillet Mike Tillet 6/15/2021
Print Name Signature Date

Individual School Project Officer(s) (See page iii)

Third Party Sampling Firm: SEC Inc.
(Note N/A if Third Party not involved) Name of Firm

J Bonanno [Signature] 6/15/21
Print Name Signature Date

Laboratory: PAS Labs
Name of Laboratory

Laboratory Manager: Kelly Hogan Kelly Hogan 6/15/21
Print Name Signature Date

Laboratory QA Officer: Mark Feitelson [Signature] 6/15/21
Print Name Signature Date

For additional laboratories conducting sampling and or analysis use additional sheet for sign-off.



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Shrewsbury Boro, 20 Obre Place, Shrewsbury, NJ
PAS Project ID : P21-06890

Matrix : Drinking Water
Report Date : 7/16/2021

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P21-06890-01	SB11 Retest 1st Draw	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/13/21 08:51	7/14/21 13:26
P21-06890-02	SB11 Retest Flush (30)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/13/21 08:53	7/14/21 13:30

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feltelson, Lab. Director

Appendix D
Excel Template for Lead Results

Client : Strategic Environmental
 Project ID : Shrewsbury Boro, 20 Obre Place, Shrewsbury, NJ

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
SB11 Retest 1st Draw	N	P21-06890-01	PAS	NJDEP 15001	7/13/2021	8:51	SM 3113 B	7/14/2021	13:26	0.890	2.00	1	N	ND
SB11 Retest Flush (30)	Y	P21-06890-02	PAS	NJDEP 15001	7/13/2021	8:53	SM 3113 B	7/14/2021	13:30	-0.13	2.00	1	N	ND

CHAIN OF CUSTODY

Customer: Strategic Environmental Svcs.
 Address: 25 Butternut Lane
 Bayville, NJ 08721
 Phone: (732) 269-4204

School Name: St. Ann's School
 School Address: 200 Blue Pine
 Sampled By: [Signature]
 Print Name: [Signature]
 RESULTS TO: [Signature]

Sample ID Location	Date Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Preserv	# Containers	Glass or Plastic	Analysis	LAB ID
SB11 Retest 1st Draw	8:51	DW	Grab			1	250ml Plastic	Lead	P21-06890-01
SB11 Retest Flush (30)	8:53	DW	Grab			1	250ml Plastic	Lead	P21-06890-02
* American Plumber Filter model W385-PR Lines & Filter & FAUCET * Kingston BRASS FAUCET Model KB 6621LL		DW	Grab			1	250ml Plastic	Lead	
		DW	Grab			1	250ml Plastic	Lead	
		DW	Grab			1	250ml Plastic	Lead	
		DW	Grab			1	250ml Plastic	Lead	
		DW	Grab			1	250ml Plastic	Lead	
		DW	Grab			1	250ml Plastic	Lead	
		DW	Grab			1	250ml Plastic	Lead	
		DW	Grab			1	250ml Plastic	Lead	
		DW	Grab			1	250ml Plastic	Lead	
		DW	Grab			1	250ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED, PRESERVED IN LAB.

Page 1 of 1

Deliverables: PDF Std. PDF Reduc. PDF Full EDD Date/Time Preserved: 1/13/10 11:00

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PREP CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name	Signature	Date + Time
Relinquished	[Signature]	[Signature]	1/13/10
Received	Lynn Spina	[Signature]	9:33 am
Relinquished			
Received			
Relinquished			
Received			